

PARAMETERS	HEALTH CANADA RECOMMENDATIONS (2014)	QUEBEC REGULATION DRINKING WATER QUALITY (Q-2,r.40)	DRINKING WATER		
			CONCENTRATION		
			MIN.	AVE.	MAX.
Physical Properties					
pH (units)	6.5 - 8.5	6.5 - 8.5	6.90	7.13	7.30
Turbidity (N.T.U.)	≤1.0	≤5 / ≤1 ²	0.10	0.16	0.28
Biological Characteristics					
			ANNUAL AVERAGE		
Total coliforms (C.F.U./100ml)	>90% ABS ⁴	>90% ABS ⁴	99.9% ABS		
E. coli (C.F.U./100ml)	ABS ⁴	<1 or ABS ⁴	100% ABS		
Inorganic and Organic Chemical Characteristics (mg/l)					
Antimony (Sb)	≤0.006	≤0.006	0.00009	0.00009	0.00009
Aluminum (Al) **	<0.1	--	0.01539	0.02917	0.05210
Silver (Ag) **	--	--	<0.00003	<0.00003	0.00003
Arsenic (As)	≤0.010	≤0.010	0.00030	0.00030	0.00030
Barium (Ba)	≤1.0	≤1.0	0.01683	0.01683	0.01683
Bore (B)	≤5	≤5.0	<0.02	<0.02	<0.02
Bromated (BrO ₃) *	≤0.01	≤0.010	N.D.	N.D.	N.D.
Cadmium (Cd)	≤0.005	≤0.005	<0.00003	<0.00003	<0.00003
Calcium (Ca) **	--	--	9.11	16.79	28.42
Chromium (Cr)	≤0.05	≤0.050	0.00003	0.00003	0.00003
Cobalt (Co) **	--	--	<0.00002	<0.00002	0.00004
Copper (Cu) ⁷	≤1.0 ¹	≤1.0	0.00597	0.00597	0.00597
Cyanides (CN)	≤0.2	≤0.20	<0.004	<0.004	<0.004
Iron (Fe) **	≤0.3 ¹	--	<0.00432	0.00718	0.01000
Fluorides (F)	≤1.5	≤1.50	0.08	0.08	0.08
Magnesium (Mg) **	--	--	2.18	4.25	7.32
Manganese (Mn) **	≤0.05 ¹	--	0.00148	0.00417	0.00757
Mercury (Hg)	≤0.001	≤0.001	<0.00003	<0.00003	<0.00003
Nickel (Ni) **	--	--	<0.00003	0.00045	0.00114
Nitrites (NO ₂ -N) + nitrates (NO ₃ -N)	≤1 + ≤10	≤10.0	0.16	0.27	0.41
Lead (Pb) ⁷	≤0.010	≤0.010	0.00007	0.00003	0.00014
Potassium (K) **	--	--	0.72	1.09	1.44
Selenium (Se)	≤0.05	≤0.010	<0.0002	<0.0002	<0.0002
Sodium (Na) **	≤200 ¹	--	10.76	13.53	21.07
Uranium (U)	≤0.02	≤0.020	0.00002	0.00002	0.00002
Zinc (Zn) **	≤5.0 ¹	--	<0.00017	0.00145	0.00245

PARAMETERS	HEALTH CANADA RECOMMENDATIONS (2014)		QUEBEC REGULATION DRINKING WATER QUALITY (Q-2,r.40)	DRINKING WATER
				MAXIMUM DETECTED (µg/L)
Carbamates				
Bendiocarb *	-		27	N.D.
Carbaryl *	90		70	N.D.
Carbofuran *	90		70	N.D.
Volatile Organic Compounds (VOC)				
1,1,1,2-Tétrachloroethane	-		-	N.D.
1,1,1-Trichloroethane	-		-	N.D.
1,1,2,2-Tétrachloroethane	-		-	N.D.
1,1,2-Trichloroethane	-		-	N.D.
1,1-Dichloroethane	-		-	N.D.
1,1-Dichloroethylene	14		10	N.D.
1,1-Dichloropropene	-		-	2.88
1,2,3-Trichlorobenzene	-		-	N.D.
1,2,3-Trichloropropane	-		-	N.D.
1,2,4-Trichlorobenzene	-		-	N.D.
1,2,4-Triméthylbenzene	-		-	N.D.
1,2-Dibromo-3-chloropropane	-		-	N.D.
1,2-Dibromoethane	-		-	N.D.
1,2-Dichlorobenzene	200	3 ¹	150	N.D.
1,2-Dichloroethane	5		5	N.D.
1,2-Dichloropropane	-		-	N.D.
1,3,5-Triméthylbenzene	-		-	N.D.
1,3-Dichlorobenzene	-		-	N.D.
1,3-Dichloropropane	-		-	N.D.
1,4-Dichlorobenzene	5	1 ¹	5	N.D.
1-Chlorobutane	-		-	N.D.
1-Propene,3-chloro	-		-	N.D.
2,2-Dichloropropane	-		-	N.D.
2-Butanone	-		-	N.D.
2-Chlorotoluene	-		-	N.D.
2-Nitropropane	-		-	N.D.
4-Chlorotoluene	-		-	N.D.
4-Isopropyltoluene	-		-	N.D.
Acrylonitrile	-		-	N.D.
Benzene	5		0.5	N.D.
Bromobenzene	-		-	N.D.
Bromochloromethane	-		-	N.D.
Bromoform	-		See Note 3	N.D.
Bromodichloromethane	-		See Note 3	8.85
Bromomethane	-		-	N.D.
Chloroacetonitrile	-		-	N.D.
Chlorobenzene	80	30 ¹	60	N.D.
Chlorodibromomethane	-		See Note 3	2.20
Chloroethane	-		-	N.D.
Chloroform	-		See Note 3	38.14
Chloromethane	-		-	N.D.
Vinyl chloride	2		2	N.D.

PARAMETERS	HEALTH CANADA RECOMMENDATIONS (2014)		QUEBEC REGULATION DRINKING WATER QUALITY (Q-2,r.40)	DRINKING WATER
				MAXIMUM DETECTED (µg/L)
cis-1,2-Dichloroethylene	-	-	-	N.D.
cis-1,3-Dichloropropene	-	-	-	N.D.
Dibromomethane	-	-	-	N.D.
Dichlorodifluoromethane	-	-	-	N.D.
Dichloromethane	50	-	50	N.D.
Diethylether	-	-	-	N.D.
Carbon disulfide	-	-	-	N.D.
Ethylbenzene	140	1.6 ¹	-	0.40
Hexachlorobutadiene	-	-	-	N.D.
Hexachloroethane	-	-	-	N.D.
Isopropylbenzene	-	-	-	N.D.
Methacrylonitrile	-	-	-	N.D.
Methyl acrylate	-	-	-	N.D.
Methyl methacrylate	-	-	-	N.D.
MTBE(methyl tert-butyl ether)	-	15 ¹	-	N.D.
m-Xylene + p-Xylene + o-Xylene	90	200 ¹	-	1.78
Naphthalene	-	-	-	N.D.
n-Butylbenzene	-	-	-	N.D.
n-Propylbenzene	-	-	-	N.D.
Propionitrile	-	-	-	N.D.
sec-Butylbenzene	-	-	-	N.D.
Styrene	-	-	-	N.D.
tert-Butylbenzene	-	-	-	N.D.
Tetrachloroethylene	30	-	25	N.D.
Carbon tetrachloride	2	-	5	N.D.
Tetrahydrofurane	-	-	-	N.D.
Toluene	60	24 ¹	-	0.66
trans-1,2-Dichloroethylene	-	-	-	N.D.
trans-1,3-Dichloropropene	-	-	-	N.D.
Trans-1,4-dichloro-2-butene	-	-	-	N.D.
Trichloroethylene	5	-	5	N.D.
Trichlorofluoromethane	-	-	-	N.D.
Trihalomethanes (THM) (total)	-	-	See Note 3	42.20
Trihalomethanes (THM) (total) – Annual mean concentration	100	-	80 ³	39.82
Phenolic Compounds				
2,3,4,6-Tetrachlorophenol *	100	1 ¹	70	N.D.
2,4 -Dichlorophenol *	900	0.3 ¹	700	N.D.
2,4,6-Trichlorophenol *	5	2 ¹	5	N.D.
Pentachlorophenol *	60	30 ¹	42	N.D.
Glyphosate				
Glyphosate *	280	-	210	N.D.
Polycyclic Aromatic Hydrocarbons (PAH)				
Benzo(a)pyrene *	0.01	-	0.01	N.D.

PARAMETERS	HEALTH CANADA RECOMMENDATIONS (2014)	QUEBEC REGULATION DRINKING WATER QUALITY (Q-2,r.40)	DRINKING WATER
			MAXIMUM DETECTED (µg/L)
Triazine Herbicides			
Atrazine and metabolites *	5	3.5	N.D.
Cyanazine *	-	9	N.D.
Metribuzine *	80	60	N.D.
Simazine *	10	9	N.D.
Chlorophenoxy Acid and Trichloroacetate Pesticides			
2,4-D *	100	70	N.D.
Dicamba *	120	85	N.D.
Dinoseb *	-	7	N.D.
Picloram *	190	140	N.D.
Organochlorine Pesticides			
Metolachlor *	50	35	N.D.
Methoxychlor *	-	700	N.D.
Trifluralin *	45	35	N.D.
Organophosphorus Pesticides			
Azinphos-methyl *	20	17	N.D.
Chlorpyrifos *	90	70	N.D.
Diazinon *	20	14	N.D.
Dimethoate *	20	14	N.D.
Diuron *	150	110	N.D.
Malathion *	190	140	N.D.
Parathion *	-	35	N.D.
Phorate *	2	1.4	N.D.
Terbufos *	1	0.5	N.D.
Others			
Bromoxynil *	5	3.5	N.D.
Methyl-Diclofop *	9	7	N.D.
Diquat *	70	50	N.D.
Paraquat *	10	7	N.D.

*: Analyzed by an outside accredited laboratory.

**.: At the exit of water treatment plant.

N.D.: Not detected, lower than the detection limit method.

D.: Detected, but cannot determine quantity.

Notes:

- 1: Esthetical or organoleptic reasons.
- 2: Turbidity must be equal or under 5 NTU and must not overpass 1.0 NTU for more than 5 % of total measures taken within 30 days.
- 3: The annual mean concentration of total THM (chloroform, bromodichloromethane, chlorodibromomethane and bromoform) must not exceed 80 µg/L (samples taken at the end of drinking water distribution network).
- 4: ABS: absence.
- 5: Health reasons objectives.
- 6: Maximum obtained for a sampling site.
- 7: Lead and copper level at the center of water distribution network. When water samples are taken from old pipes (before 1970) results are shown below.

PARAMETERS	HEALTH CANADA RECOMMENDATIONS (2014)	QUEBEC REGULATION DRINKING WATER QUALITY (Q-2,r.40)	DRINKING WATER CONCENTRATION		
			MIN.	AVE.	MAX.
Copper and Lead (mg/l)					
Copper (Cu)	≤1.0 ¹	≤1.0	0.00454	0.03643	0.09271
Lead (Pb)	≤0.010	≤0.010	0.00003	0.00038	0.00212